

Data Sheet

UPS-456-TA Instant Leak Stopper 50mm wide x 2.9m (Pack of 10)

Data Sheet Type	Final
Material Reference	UPS-456-TA
Polymer	EPDM
Date Issued	29/09/20



Description

Part of the Thistlebond range of rapid curing, Emergency Pipe Repair Bandages specifically developed to repair leaking pipes. Instant Leak Stopper is designed for all pipe systems and is manufactured from high temperature EPDM Rubber with a wide chemical resistance. It solves leaks up to 10 bar, can be fitted under pressure and requires no special tools for installation

Specifications	Values	Test Methods
Highest Recommended Working Temperature	120 °C	None
Lowest Recommended Working Temperature	-40 °C	None
Maximum Pressure	10.26 bar (149 PSI)	None

Purposes



Abrasive Resistance



Acid Resistance



Chemical Resistant



Flame Retardent



Oil Resistance



Ozone Resistance



Self Extinguishing



Tear Resistant



Water Resistant



Wear Resistant



Weather Resistance

**Important Notes about this Material Data Sheet**

This datasheet has been carefully compiled to advise you, our customer, in the best possible way. The information, figures, test values, and data correspond to actual engineering standards and are the result of many years of tests and trials. As individual operating conditions influence the application of each product, the information supplied in this datasheet can only be seen as a rough guideline. In every case it is the sole responsibility of the customer to evaluate his individual requirements, in particular whether the specified properties of our products are sufficient for the intended use. This datasheet is subject to alteration without prior notice . All mentioned values contained herein are guiding values representing long-term experience averages. Please be aware that Test Results for individual Material Batches will only be provided if requested at the time of order and may be subject to additional charges and/or lead times. This Data Sheet supersedes all previous data sheets and any other data previously provided

---

either Verbally, Electronic or Written, with reference to the above Material Grade.